

CERTIFICATE POSTING REQUIREMENTS

This certificate and accident contact information must be placed under glass in a conspicuous place on or near the boiler for which it is issued. Failure to meet this requirement may result in sanctions or penalties.

IMPORTANT ACCIDENT INFORMATION:

In case of a serious accident, such as an explosion, the owner/operator shall immediately notify the Texas Department of Licensing & Regulation at 512-463-6599 and/or via email at

boilers@license.state.tx.us

After the accident, neither the boiler nor any of its parts shall be removed or disturbed before an inspection has been made by the Chief Boiler Inspector or his designee, except for the purpose of saving human life or preventing further damage.

Web site: www.license.state.tx.us

FOR CERTIFICATE QUESTIONS

Email: CSBoiler@license.state.tx.us

(800) 722-7843 or (512) 539-5707

FOR TECHNICAL QUESTIONS

Email: boilers@license.state.tx.us

(512) 539-5717

ARPT WESTERN PLACE OWNER LLC
6000 WESTERN PL STE 107
FORT WORTH TX 76107

BOILER CERTIFICATE OF OPERATION

Inspection Type:
EXTERNAL

Date of Inspection:
SEPTEMBER 04 2012

Certificate Expiration Date:
SEPTEMBER 04 2015

Location:

ARPT WESTERN PLACE OWNER LLC
6000 WESTERN PL STE 107
FORT WORTH TX 76107

Texas Boiler Number:

204444

Manufacturer:
PVI IND INC


National Board Number:
096703

Manufacturer's Serial Number:
129896703

Pressure Allowed: **125 psig**

S/SR Valve Setpoint: **125 psig**

The described boiler is authorized to operate until the expiration date shown unless sooner withdrawn or revoked for cause.



William H. Kuntz, Executive Director

CERTIFICATE NUMBER: **201210170101**